

MONTHLY AC MOTOR INSPECTION CHECKLIST



	Motor 1	Motor 2	Motor 3
Note any drops in output			
Check for oil or water leaks			
Visual inspection for scorch marks and general damage			
Verify that air inlets are not plugged			
Check for abnormal sounds			
Check for abnormal smells			
Inspect anchorage and base			



Inspect other foundation elements – bedplates, anchor bolts, shaft extensions, couplings & guards			
Inspect for dirt or grease build-up – clean if necessary			
Inspect bearings – check for grease			
Check for dirty or old oil			

Inspection completed by:

Date inspected:

Next inspection due:

Next professional service due: